

April 7, 2011

ELKHART PRODUCTS CORP.
PERRY RICHARDS
1255 OAK ST
ELKHART IN 46514

Re: Description: FITTINGS, COPPER
Manufacturer: ELKHART PRODUCTS CORP.
Product Name: XPRESS COPPER & COPPER ALLOY FITTINGS
Model Number(s): ADAPTER 803 C X F: 1/2" X 3/8" THRU 2" X 2"; ADAPTER 804 C X M: 1/2" X 3/8" THRU 4" X 4"; FEMALE STREET ADAPTER 803-2 FTG X F: 1/2" X 3/8" THRU 2" X 2"; MALE STREET ADAPTER 804-2 FTG X M: 1/2" X 3/8" THRU 2" X 2"; TUBE CAP 817 C: 1/2" THRU 4"; COUPLING 800 C X C WITH STOP: 1/2" THRU 4"; COUPLING 801 C X C WITHOUT STOP: 1/2" THRU 2"; COUPLING 8011-R C X C: 3/4" X 1/2" THRU 2" X 1-1/2"; CROSS-OVER 836 C X C: 1/2" AND 3/4"; 1"; ELBOW 45 DEGREE 806 C X C: 1/2" THRU 4"; ELBOW 90 DEGREE 807 C X C: 1/2" THRU 4"; ELBOW 45 DEGREE STREET 806-2 FTG X C: 1/2" THRU 4"; ELBOW 90 DEGREE STREET 807-2 FTG X C: 1/2" THRU 4"; ELBOW 90 DEGREE 8707-3 C X F: 1/2" X 3/4" THRU 2" ; 90 DEGREE DROP EAR ELBOW 8707-3-5 C XF: 1/2" AND 3/4"; ELBOW 90 DEGREE 8707-4 C X M: 1/2" THRU 2"; 125 CLASS COMPANION FLANGE 8741: 2", 2-1/2", 3" AND 4"; FITTING REDUCER 818 FTG X C: 3/4" X 1/2" THRU 4" X 3"; TEE 811 C X C X C: 1/2" THRU 4"; TEE 8712 C X C X F: 1/2" THRU 4" X 4" X 2"; TUBE CAP 817: 1/2" THRU 4"; UNION 8733-3 C X F: 1/2" THRU 2"; AND UNION 88733-4 C X M: 1/2" THRU 2"; AND UNION 8733 C X C: 1/2" THRU 2".
Product File No: 20110101

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (8) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following use(s)
 - a. Water distribution piping aboveground
 - b. Water distribution piping belowground
 - c. Water service pipe
- Approval is issued for this product because the design of the product meets the intent of s. Comm 84.40 (8), Wis. Adm. Code that requires mechanical compression type joints for water supply which use flexible elastomeric seals to be suitable for potable water. The intent of the code is met since this product provides an acceptable elastomeric seal.

ELKHART PRODUCTS

Page 2

April 7, 2011

20110101

- This product may be used to join together copper that complies with ASTM B88.
- The fittings must be labeled with the manufacturer's name or trade mark and fitting size.

This approval supersedes the approval issued on August 16, 2006 under product file number 20060273.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060273.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov